



The Decision You Make May Save A Life!

123 Columbia Court North • Suite 201 • Chaska, MN 55318

952-448-7377 • FAX: 952-448-2613

Fire Retardant "HOT LINE" 1-800-913-9385

e-mail: info@fireretardantsinc.com

Visit Our Web Site at www.fireretardantsinc.com

BURN BARRIER™ EFR-5 EXTERIOR FLAME RETARDER FOR FABRIC

Product Description:

Exterior Flame Retarder for fabric is a specially formulated solvent-based compound, designed to retard the burning of fabrics which are exposed to weather. It may not leach out, even when exposed to a continuous hose stream. It is recommended for use on welding curtains, canopies, dividers, awnings and tents. Properly treated materials will meet the requirements of NFPA 791-75. Treated materials will be water repellent as well.

Application:

Stir and mix thoroughly before applying. Flame Retarder may be applied by brush, spray or dipping. In all cases, fabric should be completely saturated.

Flame tests should be conducted on small dry sample pieces of identical fabric, treated at the same time, to insure that proper flame protection has been provided. In some cases, it may be necessary to apply a second application to obtain the desired flame retardancy. Treated fabrics will be stiffer than untreated fabrics. Dark fabrics will show discoloration in the form of whiting. To overcome whiting on dark fabrics, small amounts of universal paint colorants (2 oz. max. per gallon) maybe added to tint material to approximate color of fabric.

Coverage:

One gallon will treat approximately 450 ounces of cotton duck material.

Clean-up:

Tools and equipment should be thoroughly cleaned using Xylol or (Exxon Aromatic SC-100 solvents.)

Packaging:

1 gallon (4 per carton), 5 gallon pails and 55 gallon drums.

Information provided herein is based on tests believed to be reliable. Inasmuch as Fire Retardants inc. has no control over the use or application to which others may put this material, we make no guarantee or warranty. Our products are sold on the condition that each user of the material make their own evaluation to determine the material's suitability for their own particular use.

CAUTION: It is recommended that a test application be completed prior to end use.